



NOTE 1: USE 6" ANCHORING PIPE & COUPLINGS. IF PIPE LENGTH IS GREATER THAN 3 FEET, USE ANCHOR RODS.

CITY OF EMERSON WATER & SEWER DEPARTMENT	FIRE HYDRANT ASSEMBLY CONSTRUCTION STANDARD	DATE: 8/15/2008	STANDARD DETAIL NO. 5.08
		REVISION DATE	
		REVISION DATE	
		REVISION DATE	
		REVISION DATE	